APPENDIX - XII

FIRE SAFETY CERTIFICATE

No. LSG/KOTA NORTH/FIRE NOC/2025-26/52908 Dated: 31/05/2025

Certified that the **Akshay Public School, at Ujjwal Vihar, Borkheda, Baran Road, Kota (Raj.)** comprised of **NIL** basement(s) and Ground + 3 upper floors owned / occupied **Akshay Public School, Ujjwal Vihar, Borkheda, Baran Road, Kota (Raj.)** have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on _____ in the presence of **Amit Dhariwal, Secretary, Civil Lines, Rajbhawan Road, Nayapura, Kota (Raj.)** and that the building/ premises is fit for occupancy upto classes **Nursery to XII** With effect from 31/05/2025 for a period of 02 year in accordance with rule and subject to compliance of specific conditions as appended:-

1.
2.
3.
4.

Issued on _____ at Nagar Nigam, Kota North by

*Strike out whichever is not applicable.

Signature with Seal: RAKESH VYAS राकेश व्यास मुख्य अग्निशमन अधिकारी नगर निगम कोटा उ./द.

Name : Mr. Rakesh Vyas

Designation : Chief Fire Officer

Name & Address of Department/ Office: Municipal Corporation Kota-N/S

To

Akshay Public School
Ujjwal Vihar, Borkheda, Baran Road,
Kota (Raj.)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to empty condition of fire extinguishers and non operational of fire fighting system.
(reasons to be recorded).

(Name and designation of the authorized signatory)

*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.